



PRODUCT NUMBER: 2091906

ELECTROSOFT CLASS 0

For electrical work with a maximum voltage of 1000 volts. Must be used with a leather overglove.

Overview

Reference Number

2091906

Product Type

Gloves

Range

Electrical Protection

Line

Latex

Brand

Sperian

Brand formerly known as

ELECTROSOFT

Industry

- Energy or Electricity
- Maintenance
- Telecoms

Product Use

For electrical work with a maximum voltage of 1000 volts. Must be used with a leather overglove.

Features & Benefits

Feature

Beige natural latex insulating glove
Category RC

Benefit

COMFORT

Its ergonomic shape and lightly powdered interior make the glove easy to slip on and off.

RESISTANCE

Its natural latex base offers high dielectric characteristics.
Its thickness ensures good dexterity while offering protection up to 1,000 volts.

SAFETY

It must be used with a leather overglove.
The longer length (41 cm) helps to protect the forearm from dielectric risks.

Technical Description

Description

CE CATEGORY : III Irreversible risks
In accordance with standards :
EN 60 903-2003
CEI 903-2002

CHARACTERISTICS :

Beige natural latex insulating glove
Category RC

Product Technology

Dipped Gloves

Glove/liner color

Beige

Coating Type

Latex

Length

41 cm

Thickness

1 mm

Harmlessness

In conformity with European standards

Dexterity

Class 0

Sizes

8 à 11

EN 407 - Heat and/or Fire

Behaviour and/or fire	n/a
Resistance to contact heat	n/a
Resistance to convective heat	n/a
Resistance to radiant heat	n/a
Resistance to small metal splashes	n/a
Resistance to molten metal splashes	n/a

EN 388 - Mechanical Hazards Abrasion Resistance

Abrasion resistance	n/a
Cutting resistance	n/a
Tear resistance	n/a
Puncture resistance	n/a

EN 511- Protection in cold temperatures:

Resistance to conductive cold	n/a
Resistance to contact cold	n/a
Water permeability	n/a

EN 381-7

Chainsaw protection	n/a
---------------------	-----

EN 12477

Protective gloves for welders	n/a
-------------------------------	-----

Packaging Label**Tagging**

CE SPERIAN
 2091906 XX
 EN 60903-2003
 CEI 903-2002

Certifications


EC Category PPE

3

Quality Assurance

ISO 9001 / 2000

EC Attestation

 EC Attestation

EC Attestation Number

0077/016/078/09/93/0001 - EXT 02/10/06

Photos & Images

We're sorry, there are no images available at this time.

Additional Information

User Information Sheet

106

Maintenance

Life Cycle

Gloves that are used frequently should be tested at intervals less than 6 month.

Gloves that are used only occasionally should be tested after each use and, in any case, at intervals of not more than 12 months.

Gloves held in stock should be retested at intervals not exceeding 12 months.

Storage Information

Store in original packaging (Opaque and anti UV packaging used for protection and instructions for use). Do not compact or fold.

Do not expose to heat sources (sunlight, radiators, artificial light).

Store between 10°C and 21°C.

Care Instructions

Inspection : Before each use, carry out a visual inspection and check the glove inflation. Any puncture or perforation makes the gloves unusable.

Precautions : Do not expose to solvents or chemicals that may cause deterioration. Do not use the glove when damp.

Cleaning : use water and soap. Dry below 65°C with ambient humidity.

Honeywell

Honeywell Safety Products Australia
Pty Ltd
43 Garden Boulevard,
Dingley, Victoria 3172
Australia Tel: 1300 139 166
New Zealand Tel: 0800 322 200

[View other region sites](#)
© 2011 Honeywell International Inc.