



PRODUCT NUMBER: 2091903

ELECTROSOFT CLASS 00

For electrical work with a maximum voltage of 500 volts. Must be used with a leather overglove.

Overview

Reference Number

2091903

Product Type

Gloves

Range

Electrical Protection

Line

Latex

Brand

Sperian

Brand formerly known as

ELECTROSOFT

Industry

• Energy or Electricity • Maintenance • Telecoms

Product Use

For electrical work with a maximum voltage of 500 volts. Must be used with a leather overglove.

Features & Benefits

Feature

Beige natural latex insulating glove
Cut edge
Category AZC

Benefit

COMFORT

Its ergonomic shape and lightly powdered interior make the glove easy to slip on and off.

RESISTANCE

Its natural latex base offers high dielectric characteristics.
Its thickness (0.5 mm) ensures good dexterity while offering protection up to 500 volts of use.

SAFETY

It must be used with a leather overglove.

Technical Description

Description

CE CATEGORY : III Irreversible risks
In accordance with standards :
EN 60903-2003
CEI 903-2002

CHARACTERISTICS :

Beige natural latex insulating glove
Category AZCv

Product Technology

Dipped Gloves

Glove/liner color

Beige

Coating Type

Latex

Length

36 cm

Thickness

0.5 mm

Harmlessness

In conformity with the European standards

Dexterity

Class 00

Sizes

7 to 11

EN 407 - Heat and/or Fire

Behaviour and/or fire	n/a
Resistance to contact heat	n/a

Resistance to convective heat	n/a
Resistance to radiant heat	n/a
Resistance to small metal splashes	n/a
Resistance to molten metal splashes	n/a

EN 388 - Mechanical Hazards Abrasion Resistance

Abrasion resistance	n/a
Cutting resistance	n/a
Tear resistance	n/a
Puncture resistance	n/a

EN 511- Protection in cold temperatures:

Resistance to conductive cold	n/a
Resistance to contact cold	n/a
Water permeability	n/a

EN 381-7

Chainsaw protection	n/a
---------------------	-----

EN 12477

Protective gloves for welders	n/a
-------------------------------	-----

Packaging Label

Tagging

CE SPERIAN
2091903 XX
EN 60903-2003
CEI 903-2002

Certifications

EC Category PPE

3

Quality Assurance

ISO 9001 / 2000

EC Certificate Number

0

EC Attestation

EC Attestation

EC Attestation Number

0077/016/078/03/94/0001 EXT 01/06/06

Photos & Images

We're sorry, there are no images available at this time.

Additional Information**User Manual**

UI 106

User Information Sheet

106

Maintenance**Life Cycle**

Gloves that are used frequently should be tested at intervals less than 6 month.

Gloves that are used only occasionally should be tested after each use and, in any case, at intervals of not more than 12 months.

Gloves held in stock should be retested at intervals not exceeding 12 months.

Storage Information

Store in original packaging (Opaque and antiUV packaging used for protection and instructions for use).

Do not compact or fold.

Do not expose to heat sources (sunlight, radiators, artificial light). Store between 10°C and 21°C.

Care Instructions

Inspection : Before each use, carry out a visual inspection and check the glove inflation.

Any puncture or perforation makes the gloves unusable.

Precautions : Do not expose to solvents or chemicals that may cause deterioration. Do not use the glove when damp.

Cleaning : use water and soap. Dry below 65°C with ambient humidity



Honeywell Safety Products Australia
Pty Ltd
43 Garden Boulevard,
Dingley, Victoria 3172
Australia Tel: 1300 139 166
New Zealand Tel: 0800 322 200

[View other region sites](#)
© 2011 Honeywell International Inc.